

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 4076-1463:100 Page 1 of 1

**CATEGORY:** Smoke & Draft Control for Fire Door

**LISTEE:** Smoke Guard Corporation, 11420 Executive Drive, Boise, ID 83702  
Contact: Bill Ziegert (208) 383-3789 FAX (208) 376-1600

**DESIGN:** Model SMOKE GUARD SMOKE CONTAINMENT SYSTEM MODELS 200, \*400 AND \*600. System includes a curtain consisting of a \*minimum 1 -mil thick reinforced transparent polyimide film attached to a flexible magnet. \*Units consist of a drive pulley on the outside of the threshold assembly connected to a cabling system. The housing is a \*sheet metal container. An \*electro/electronic drive control system rewinds the film back into the housing. Refer to listee's printed data sheet and \*ICC (International Code Council) ES Report No. 4968 for additional detailed product description and operational considerations.

**RATING:** 120 VAC Primary, 12VDC Secondary – Model 600.  
120 VAC Primary, 90VDC Secondary – Model 200, 400.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and Omega Point Laboratory label.

**APPROVAL:** Listed as smoke and draft control system for use with separately listed fire-rated elevator hoistway doors. Installation and application are subjected to approval by the authority having jurisdiction when used in lieu of separate elevator lobby.

**NOTE:** The smoke detector used in conjunction with the system shall be California State Fire Marshal listed.

\*Rev. 5-22-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager